

| | | | |
|---|---|--|-------------------------------|
| a | Supplier's name | CLAUSIUS | |
| b | Models | classic P H 1-8 / classic P HC 1-8 | |
| c | Space heating application | Low temperature (35 °C) | Medium temperature (55 °C) |
| d | Energy efficiency class (average climate) | A++ | A++ |
| e | Rated heat output (average climate) | 7 kW | 7 kW |
| f | Annual energy consumption for space heating (average climate) | 2572 kWh | 2902 kWh |
| g | Energy efficiency class for space heating (average climate) | 227 % | 201 % |
| h | Sound power level (L _{WA}) | 42 dB | |
| i | Possibility of using only during off-peak hours | Yes | |
| j | Specific precautions that shall be taken into account for assembled, installation and maintained operations | All installation and maintained operations will always be made by qualified personnel and following the instructions provided in the product manual. | |
| k | Rated heat output (cold climate) | 7 kW | 7 kW |
| | Rated heat output (warm climate) | 7 kW | 7 kW |
| l | Annual energy consumption for space heating (cold climate) | 3008 kWh | 3401 kWh |
| | Annual energy consumption for space heating (warm climate) | 1686 kWh | 1891 kWh |
| m | Energy efficiency class for space heating (cold climate) | 232 % | 206 % |
| | Energy efficiency class for space heating (warm climate) | 225 % | 201 % |
| n | Sound power level (L _{WA}) | 0 dB | |

Contact information
CLAUSIUS SYSTEMS S.L.
(CEO2 GREEN S.L)

Polígono Industrial
PP Sur – PPI 5 Naves 8 y 9
36475 O Porriño (Pontevedra)
SPAIN

Edificio Fundación
Campus Universitario de Vigo
36310 Vigo (Pontevedra)
SPAIN

+34 886 11 36 11
info@clausius.es
www.clausius.es